



## F-Sector LOTO


This box should contain the following keys:

Beamline Feeder MOS 89 key

F-Sector F17B3 Lockout key

It covers exposed bus lockout for the following areas in the tunnel:

F0    F1    F2    F3    F4



- This LOTO does not cover correction elements, vacuum systems, water systems, or other equipment not powered by MOS 89 or DS-F17B3.
- If you have any questions about what is covered with this LOTO ask the MCR Crew Chief.